


Trajectory of Storage

Displacing and Replacing

Conventional Generation

Michael Jacobs
October 2017

Storage deployments displacing generation




2009 Reserves
Chile, Hawaii

2012 Freq. Reg. PJM, NY, NE

2016 Peak Plant California

Chile 2009 - 2011






© NEC Energy Solutions, Inc. – Used with Permission

Map of Northern Chile Interconnected System

Chile Reserve in Storage







Hawaii 2009 - 2011



Smoothing in Hawaii




Hawaii Contingency Reserve




Battery responding to frequency disturbance

Power Pools Manage Variability



ISO-NE & PJM 2008 -2012


FERC Order 755 developed in 2010 from demonstrations including flywheels and batteries.



PJM Regulation Market



California 2016



CA Utility-procured & Operating

- AltaGas Pomona Energy
- Western Grid Development
- AES Escondido
- AES El Cajon
- Tesla Mira Loma


20 MW/80 MWH

5 MW/20 MWH

30 MW/120 MWH

7.5 MW/ 30 MWH

20 MW/80 MWH



2016 CAISO Inverter test at PV plant

Table 2. Measured regulation accuracy by 300 MW PV plant

Timeframe	Solar PV Plant Test Results
Sunrise	93.7%
Middle of the Day	87.1%
Sunset	87.4%

Table 3. Typical regulation up accuracy of CAISO conventional generation

	Combined Cycle	Gas Turbine	Hydro		Pump Storage Turbine	Steam Turbine
Regulation- Up Accuracy	46.88%	63.08%	46.67%	61.35%	45.31%	40%

Replace 50 Year-old Coal

Consider: Waterfront coal - 689 MW
In-service since 1958 & 1962
Heat rate 10,600 Btu/kWh
Recent capacity factor ~30%



Future is Now

Renewable energy: abundant and cost-competitive &

Storage: capable of all functions



Kauai solar and storage in 2011.

For more information, please contact

Mike Jacobs mjacobs@ucsusa.org

http://blog.ucsusa.org/mike-jacobs/how-do-we-get-to-100-percent-renewable-energy-the-role-of-storage

http://blog.ucsusa.org/mike-jacobs/what-would-we-do-with-cheap-energy-storage-batteries-722

